


| 8" DIAMETER WATTLE SPACING TABLE | |
|----------------------------------|-----------------|
| SLOPE | MAXIMUM SPACING |
| 1H:1V | 10'-0" |
| 2H:1V | 20'-0" |
| 3H:1V | 30'-0" |
| 4H:1V | 40'-0" |
| >4H:1V | ONE RUN ONLY |

NOTES:

1. COMPOST WATTLES RECOMMENDED ON SLOPES. USE STRAW WATTLES IN PAVEMENT APPLICATION.
2. ON SLOPES, INSTALL WATTLES PERPENDICULAR TO THE FLOW DIRECTION AND PARALLEL TO THE SLOPE CONTOURS. INSTALLATION SHALL BE IN ACCORDANCE WITH WSDOT STANDARD SPECIFICATION 8-01.3(10).
3. RUNOFF SHALL NOT RUN UNDER OR AROUND ROLL. ADDITIONAL STAKING MAY BE NECESSARY TO PREVENT UNDERCUTTING.
4. WATTLES SHALL BE INSPECTED REGULARLY, AND IMMEDIATELY AFTER A RAINFALL PRODUCES RUNOFF. REMOVE SEDIMENT AND ACCUMULATIONS WHEN EXCEEDING 1/2 HEIGHT BETWEEN THE TOP OF THE WATTLE AND THE GROUND SURFACE.



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

WATTLE INSTALLATION

APPROVED BY: **R. ENGLISH**

REVISION DATE
JANUARY 2018

STANDARD
DETAIL
ER-903