



**GENERAL NOTES:**

1. REFER TO 2017 CITY OF EDMONDS STORMWATER ADDENDUM FOR SETBACK (CHECKLIST 12) AND INFEASIBILITY REQUIREMENTS.

**NOTES:**

1. RAIN GARDEN SHALL BE 5 FEET MINIMUM FROM BUILDINGS WITHOUT BASEMENT AND 10 FEET MINIMUM FROM BUILDINGS WITH BASEMENTS.
2. SHEET FLOW INTO RAIN GARDEN MUST BE KEPT WIDELY DISTRIBUTED OVER A STABILIZED SURFACE (PAVEMENT, PEA GRAVEL, GRASS). IF CONCENTRATED FLOW, PROVIDE A SWALE PER STD DETAIL SD-604.
3. TOTAL HARD SURFACE AREA CONTRIBUTING RUNOFF TO RAIN GARDEN MUST BE LESS THAN 5,000 SQUARE FEET.



**CITY OF EDMONDS**  
PUBLIC WORKS  
DEPARTMENT

**TYPICAL RAIN  
GARDEN PLAN**

APPROVED BY: R. ENGLISH

REVISION DATE  
DECEMBER 2017

STANDARD  
DETAIL  
SD-601