


NOTES:

1. SLOTTED PVC UNDERDRAIN PIPE SHALL BE SDR 21, CLASS 200 PVC PIPE (ASTM D2241) OR SCH 40 PVC PIPE (ASTM D 1785).
2. SLOT DIMENSIONS ARE 0.04" TO 0.069" WIDE X 1.00" LONG SPACED ALONG PIPE AT 0.25" ON CENTER.
3. UNDERDRAIN PIPE SHALL BE 4" MINIMUM DIAMETER (PRIVATE), 8" MINIMUM DIAMETER (PUBLIC).



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

**SLOTTED PVC
UNDERDRAIN PIPE**

APPROVED BY: R. ENGLISH

REVISION DATE
DECEMBER 2017

STANDARD
DETAIL
SD-618