



**GENERAL NOTES:**

1. REFER TO THE 2017 CITY OF EDMONDS STORMWATER ADDENDUM FOR SETBACK (CHECKLIST 15) AND INFEASIBILITY REQUIREMENTS.
2. TRENCH LENGTH TO BE 10 FEET IN LENGTH FOR EVERY 5,000 SQUARE FEET OF CONTRIBUTING ROOF AREA.

**NOTES:**

1. CLEANOUTS RECOMMENDED AT PIPE BENDS.
2. GEOTEXTILE SHALL CONFORM TO WSDOT SPEC. 9-33.2(1), GEOTEXTILE FOR SEPARATION, NON-WOVEN TYPE.
3. WASHED DRAIN ROCK SHALL CONFORM TO WSDOT SPEC. 9-03.12(5), GRAVEL BACKFILL FOR DRYWELLS.



**CITY OF EDMONDS**  
PUBLIC WORKS  
DEPARTMENT

**TYPICAL PERFORATED  
STUB-OUT CONNECTION**

APPROVED BY: R. ENGLISH

REVISION DATE  
NOVEMBER 2018

STANDARD  
DETAIL  
SD-639