


NOTES:

1. SEWER PIPE SHALL BE SDR-35 AND JOINTS SHALL BE GASKETED.
2. PIPE SLOPE TO BE 2% MIN AND UP TO 50% MAX.
3. SEWER CLEANOUT COVER TO BE EAST JORDAN IRON WORKS PRODUCT #00366102 STAR PIPE COSP48L OR APPROVED EQUAL.
4. LEVELING COLLAR SHALL BE CONSTRUCTED AS FOLLOWS:
 - IN ROADWAYS PER COE STD DWG GU-424
 - IN SIDEWALK/LANDSCAPED AREAS, EITHER 24"x24"x6" DEEP CONCRETE COLLAR OR 24" DIAMETER x 6" DEEP CONCRETE COLLAR



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

SEWER CLEANOUT DETAILS

APPROVED BY: **R. ENGLISH**

REVISION DATE
JANUARY 2018

STANDARD
DETAIL
SS-200