


PROFILE VIEW

PLAN VIEW

PIPE DIAMETER A	CORE DRILL DIAMETER B	CALPICO CSL#	QTY OF CALPICO CSL
3"	6"	32	5
4"	8"	40	5
6"	10"	40	7
8"	12"	40	9



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

**VAULT THRUST BLOCK
& VAULT SEAL**

APPROVED BY: **R. ENGLISH**

REVISION DATE
JANUARY 2018

STANDARD
DETAIL
WA-111