


MATERIAL LIST:

- (A) ALL 1" SERVICES TO BE TYPE "K" SOFT COPPER TUBING
- (B) 1" BALL CORP. STOP WITH CC THREAD INLET AND COPPER (CTS) GRIP OUTLET (FORD OR MUELLER)
- (C) DUAL PURPOSE UNION
- (D) MIPT X CTS COMPRESSION FITTING BALL VALVE CURB STOP EQUAL TO FORD B84-444Q FOR 1"
- (E) **WHEN REPLACING EXISTING SERVICES:** 1" METER SETTER WITH ANGLE BALL METER VALVE 15" HIGH WITH DUAL PURPOSE UNIONS ON INLET AND OUTLET, HORIZONTAL IN HORIZONTAL, OUTLET EQUAL TO FORD VB74-15W-11-44
WHEN PLACING NEW SERVICES: USE SAME AS ABOVE AND ADD A SINGLE CHECK, EQUAL TO FORD VBH74-15W-11-44
- (F) 1" CC TAP SERVICE SADDLE EQUAL TO ROMAC 101S
- (G) IN UNPAVED AREAS: CARSON 1324 MSBCF WITH DUCTILE IRON COVER AND CAST IRON READER DOOR;
 IN PAVED AREAS: ARMOR CAST A6001946PCX12 BOX W/ A600196969 RCI LID
- (H) FOR VACANT LOT (FUTURE USE) LOCATION MARKED WITH PAINTED 2" X 4" STAKE WITH "WATER" STENCILED ON IT
- (I) 14 GA. VINYL COATED WIRE TRACER (TAPED TO PLASTIC PIPE EVERY 10') TO BE GROUNDED AT METER AND HOUSE
- (J) SCHEDULE 40 3/4" OR 1" PLUG, REMOVE WHEN CONNECTION IS MADE TO CUSTOMER LINE WITH COMPRESSION FITTING
- (K) WATER SERVICE TO HOUSE, INSTALLED BY OWNER/CONTRACTOR (PER PLUMBING CODE)
- (L) PROPERTY OWNER RESPONSIBLE FOR PURCHASING 3/4" OR 1" METER THROUGH THE CITY AT DEVELOPMENT SERVICES DEPARTMENT; CITY WILL SUPPLY AND INSTALL METER AFTER PURCHASE; IF USING 3/4" METER, CONTRACTOR WILL PROVIDE REDUCERS
- (M) BACK SIDE OF METER BOX SHALL BE SET AT THE PROPERTY LINE UNLESS APPROVED BY THE CITY ENGINEER. METER BOXES SHALL NOT BE SET IN DRIVEWAY AREAS UNLESS TRAFFIC RATED BOX IS APPROVED BY CITY ENGINEER.



CITY OF EDMONDS
 PUBLIC WORKS
 DEPARTMENT

3/4" - 1" WATER SERVICE INSTALLATION

APPROVED BY: R. ENGLISH

REVISION DATE
 AUGUST 2019

STANDARD
 DETAIL
 WA-130