


**NOTES:**

1. ACCESSES BY LW HATCH: TYPE "D" (HD-10 PEDESTRIAN LOAD; H-30 TRAFFIC LOAD) WITH SIDE OUTLET GUTTER DRAIN.
2. VAULT COVER GUTTER DRAIN SHALL CONNECT TO A DRY WELL OR CATCH BASIN.
3. SEE COE STD DTLS WA-183 AND WA-184 FOR DCDA LOCATION AND CONNECTION REQUIREMENTS.
4. IF SOIL CONDITIONS OR PRESENCE OF GROUNDWATER DO NOT ALLOW DRAINAGE OF SUMP, DRAINAGE SHALL BE DIRECTED TO ONSITE DRAINAGE SYSTEM.
5. SEE COE STD DTL WA-142A FOR PLAN VIEW.



**CITY OF EDMONDS**  
PUBLIC WORKS  
DEPARTMENT

**COMMERCIAL MULTI-FAMILY  
DOUBLE CHECK DETECTOR  
ASSEMBLY (PROFILE)**

APPROVED BY: R. ENGLISH

REVISION DATE  
**MARCH 2018**

STANDARD  
DETAIL

**WA-142B**