

COMPACTED BEDDING GRAVEL PER SECTION 9-03.12(3) OF THE WSDOT STANDARD SPECIFICATIONS

COMPACTED BEDDING GRAVEL PER SECTION 9-03.12(3) OF THE WSDOT STANDARD SPECIFICATIONS

CONCRETE SUPPORT BRICKS
NUMBER OF BRICKS REQUIRED
DEPENDS ON AMOUNT OF OVER
EXCAVATION (TYP)

CONCRETE SUPPORT BRICKS
NUMBER OF BRICKS REQUIRED
DEPENDS ON AMOUNT OF OVER
EXCAVATION (TYP)

**DUCTILE IRON TAPPING TEE
MECHANICAL JOINT SLEEVE**

INSTALLED ON CAST IRON
PIPE AND DUCTILE IRON PIPE

STAINLESS STEEL TAPPING TEE


INSTALLED ON CAST IRON PIPE AND
DUCTILE IRON PIPE

STEEL TAPPING TEE

INSTALLED ON DUCTILE IRON PIPE ONLY

NOTES:

1. STAINLESS STEEL TAPPING TEES SHALL HAVE FULL CIRCLE SEAL. BOLTS AND NUTS SHALL BE STAINLESS STEEL.
2. STEEL TAPPING TEES SHALL BE EPOXY COATED. BOLTS AND NUTS SHALL BE COR-TEN, OR STAINLESS STEEL.
3. ALL TEES AND VALVES TO BE WATER TESTED BEFORE TAP.
4. TAPPING TEE MAY NOT BE SIZE ON SIZE. TAP SHALL BE AT LEAST 2" SMALLER DIAMETER THAN THE EXISTING MAIN.



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

TAPPING TEES

APPROVED BY: R. ENGLISH

REVISION DATE
MAY 2018

STANDARD
DETAIL
WA-182