


VALVE NUT EXTENSION

EXTENSIONS ARE REQUIRED WHEN THE VALVE NUT IS MORE THAN THREE (3) FEET BELOW FINISHED GRADE.
 EXTENSIONS ARE TO BE A MINIMUM OF ONE (1) FOOT LONG. ONLY ONE EXTENSION TO BE USED PER VALVE.

NOTES:

1. ALL EXTENSIONS ARE TO BE MADE OF STEEL, SIZED AS NOTED, AND HOT DIPPED GALVANIZED.
2. INSTALL EXTENSIONS PERPENDICULAR TO THE WATER LINE VERTICAL ALIGNMENT.



CITY OF EDMONDS
 PUBLIC WORKS
 DEPARTMENT

VALVE NUT EXTENSION

APPROVED BY: **R. ENGLISH**

REVISION DATE
JANUARY 2018

STANDARD
 DETAIL
WA-185