


NOTES:

SIDE VIEW

1. PROVIDE CITY APPROVED SUPPORT FOR DEVICES LARGER THAN 1" DIAMETER.
2. OWNER SHALL FURNISH, INSTALL AND MAINTAIN THE RPBA OR RPDA AND ALL PIPING AND APPURTENANCES SHOWN ON THIS PLAN.
3. CITY WILL PROVIDE INSPECTION. INITIAL TEST OF THE RPBA OR RPDA PRIOR TO ESTABLISHMENT OF WATER SERVICE WILL BE DONE BY A STATE CERTIFIED BAT TESTER
4. REDUCED PRESSURE BACKFLOW ASSEMBLIES SHALL BE STATE APPROVED DEVICES.
5. ANNUAL TESTING OF RPBA AND RPDA REQUIRED BY OWNER.
6. DRAIN SHALL BE SIZED IN ACCORDANCE WITH AWWA CROSS CONNECTION CONTROL FIGURE 6-8 (SEE STD DETAIL SHEET E 7.11.1)
7. ENCLOSURES SHALL BE LOCATED ON PRIVATE PROPERTY.



CITY OF EDMONDS

REVISIONS		STANDARD DETAIL		
APPROVED BY	DATE	HOT BOX ASSEMBLY FOR REDUCED PRESSURE BACKFLOW ASSEMBLY (RPBA) AND RPDA		
D. GEBERT	10/6/03	DATE	SCALE	DWG NO.
D. GEBERT	4/2/07			
R. ENGLISH	10/04/11	6/16/03	NTS	<b>E 7.11</b>