


NOTE:

1. APPROVED PRESSURE VACUUM BREAKER ASSEMBLY MUST BE INSTALLED VERTICALLY, 6" MIN. ABOVE THE HIGHEST POINT OF USE AND ALL DOWN STREAM PIPING.
2. 6" MIN. ABOVE FLOOD LEVEL FOR GENERAL PLUMBING.
3. DESIGNED FOR BACK SIPHONAGE ONLY, NOT FOR BACK PRESSURE.
4. THOROUGHLY FLUSH LINES PRIOR TO INSTALLATION OF BACKFLOW PREVENTER.
5. IF A AVB IS INSTALLED INDOORS, CONSIDERATION MUST BE GIVEN TO WATER LEAKAGE IF THE BACKFLOW PREVENTER FAILS (EXCESSIVE WATER SPILLAGE)
6. DO NOT INSTALL IN AN AREA SUBJECT TO FLOODING.
7. MUST BE PROTECTED FROM FREEZING CONDITIONS.
8. THE BACKFLOW ASSEMBLY SHALL BE A STATE APPROVED MODEL.
9. A PLUMBING PERMIT IS REQUIRED- OBTAIN PERMIT FROM CITY OF EDMONDS DEVELOPMENT SERVICES.
10. NO DOWNSTREAM VALVES ARE ALLOWED.
11. THIS DEVICE DOES NOT REQUIRE TESTING BY A BACKFLOW ASSEMBLY TESTER.

(ABOVE GROUND INSTALLATION ONLY)



# CITY OF EDMONDS

## REVISIONS

APPROVED BY	DATE

## STANDARD DETAIL

### ATMOSPHERIC/ANTI-SIPHON VACUUM BREAKER ASSEMBLY 2" AND SMALLER (AVB)

DATE 6/16/03

SCALE NTS

DWG NO. E 7.16