


NOTES:

1. MINIMUM PAVEMENT COMPACTION – 91% OF RICE DENSITY.
2. SEE COE STD DTL TR-550 FOR POSSIBLE ROOT BARRIER INSTALLATION.
3. SUBGRADE AND 5/8" MINUS CSTC SHALL BE COMPACTED TO A MINIMUM OF 95% MAXIMUM DENSITY.
4. SUBGRADE INSPECTION REQUIRED PRIOR TO PLACING HMA.
5. FULL WALKWAY WIDTH RESTORATION REQUIRED FOR ANY SURFACE DISTURBANCE.



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

ASPHALT WALKWAY

APPROVED BY: **R. ENGLISH**

REVISION DATE
SEPTEMBER 2023

STANDARD
DETAIL
TR-530